

Dry Density Ratio Report



Client : Roberts Bros.	Report Number: G17058 - 17/1
Address: 123 Maple St Cooroy Qld 4563	Report Date : 29/09/2017
Job Number : G17058	Order Number:
Project : Field & Laboratory Testing	Test Method: AS1289.5.4.1
Location : Stage 2 , Chatsworth	

Page 1 of 1

Lab No :	109911	109912	109913	
ID No :	-	-	-	
Lot No :	-	-	-	
Item No :	-	-	-	
Date Sampled :	25/9/2017	25/9/2017	25/9/2017	
Date/Time Tested :	25/9/2017 / 1.40	25/9/2017 / 1.50	25/9/2017 / 2.00	
Material Source :	Site	Site	Site	
For Use As :	Fill	Fill	Fill	
Sample Location :	Lot 56 E 0462562 N 7108437 Final Fill Lvl	Lot 56 E 0462549 N 7108437 Approx 0.5m < Final Lvl	Lot 56 E 0462532 N 7108429 Approx 1.0m < Final Lvl	
Test/Layer Depth (mm)	150 /	150 /	150 /	
Max Size (mm) :	19.0	19.0	19.0	
Oversize Wet (%) :	2	9	-	
Oversize Dry (%) :	3	10	-	
Field Moisture (%) :	11.2	10.1	11.2	
MDR No :	109911	109912	109913	
Assigned MDR :	No	No	No	
Field Dry Density (t/m ³)	1.79	1.89	1.79	
MDD (t/m ³) :	1.87*	1.90*	1.88	
OMC (%) :	13.0	13.0	14.0	
Variation from OMC	1.5% dry of omc	3% dry of omc	3% dry of omc	
Field Density Method :	AS1289.5.8.1	AS1289.5.8.1	AS1289.5.8.1	
MC Method :	AS 1289.2.1.1	AS 1289.2.1.1	AS 1289.2.1.1	
Compactive Effort :	Standard	Standard	Standard	
Moisture Ratio / Spec(%) :	87.5 / -	77 / -	79.5 / -	
Dry Density Ratio (%) :	96.0	100.0	95.0	
Min Dry Dens Ratio (%)	95	95	95	

Remarks :

* - Denotes corrected for oversize

 <p>Accredited for compliance with ISO/IEC 17025-Testing</p>	APPROVED SIGNATORY  Mel Burnett NATA Accred No:1551	FORM NUMBER REP ANUC-1-3
--	---	------------------------------------