8/41 Sunshine Beach Road Noosa Junction P.O Box 2305 Noosa Heads 4567 www.callaghanandtoth.com.au Ph: 07 5474 9081 Fax: 07 54749041



16th February 2018

File No: 0828 Stg2

Chief Executive Officer Gympie Regional Council (by email)

Attention:

Mike Conroy

Dear Sir,

OPW2015-1158 Rural Residential Subdivision Stage 2 Allotment Filling

We enclose plan 0828-tests which shows the approximate locations of fill building pads and test results for allotments that have been filled.

I certify that proof rolling, inspections of pads and the test results enclosed for allotment filling have been carried out to AS3798 Level 2 standards.

Geotech S,C.Pty Ltd were subcontracted to undertake sampling and inspect the pads. Roberts Bros. personal undertook fill placement and compaction.

The frequency of density testing conducted being 42 tests for 19 house pads with one to three tests per house pad is in line with the minimum frequency recommended in table 8.1 of AS 3798-2007 for Type 2 earthworks ie.1 test per lot per layer

Yours faithfully,

Callaghan & Toth

A D Toth BE Environmental RPEQ 6069 (Env) (civil) MIEAust CPEng NPER CPESC Director

Please view www.callaghanandtoth.com.au for all information on our company profile.

CC: Roberts Brothers